City of SACRAMENTO
Community Development

300 Richards Blvd., 3rd Floor
Sacramento, CA 95811

Help Line: 916-264-5011
www.cityofsacramento.gov/cdd

Residential Electric Vehicle Supply Equipment (EVSE) Installations Submission Checklist

Article 625 – 2022 California Electrical Code

Submittal Requirements:

Level 1 Charger:

- 120v dedicated 20 amp circuit
- No electrical plans required

Level 2 Charger:

- 240v dedicated circuit
- Provide:
    1. Cut sheets
    2. Load calculations: complete the Electrical Load Calculation Worksheet (Form CDD-0213) providing the load calculation of the electrical service.
    3. Site plan (show house on lot, service, and EVSE)
    4. One-line diagram: show the service size, E.V. breaker size, E.V. conductor size and number of conductors, and EVSE