

COMMON VIOLATIONS FOR BUSINESS OWNERS

This list is meant as a guide of common violations. There may be other violations found at your business.

1. Service fire extinguishers annually and perform monthly checks. (Title 19 Division 1, 574.1)
2. Ensure fire extinguishers are mounted and/or in a cabinet per code. (CFC 906.7)
3. Fire alarm and fire sprinkler systems shall be maintained in proper working condition. (CFC 901.7)
4. Ensure required testing of fire sprinkler, fire alarm, fire pump, fire hydrant and standpipe system has been performed by a licensed contractor. (Title 19 Division 904.2) (Title 19, Section 905)
5. Make sure fire lanes are clearly marked. NO PARKING – FIRE LANE. (CFC 503.3)
6. Shall service kitchen hood extinguishing system every 6 months or after activation of the system. (CFC 904.6.1)
7. Kitchen hood is to be professionally cleaned by a qualified individual. (CFC 606.3.3)
8. Remove all extension cords used as permanent wiring. (CFC 603.6)
9. Relocatable power taps and current taps shall be directly connected to a permanently installed receptacle. (No daisy chaining). (CFC 603.5.2)
10. Portable electric heaters must be connected directly to a permanent and approved receptacle. (CFC 4102.1)
11. Ensure all electrical outlets are in good working order and have an appropriate cover plate, including no exposed wiring. (CFC 603.2.2)
12. Ensure all exiting remains unblocked, free from obstructions, and open easily. (CFC 1032.2)
13. Remove all pin and bolt locks on required exit doors. (CFC 1010.2.4)
14. Remove door stops from fire-rated doors (CFC 705.2.3)
15. Secure all compressed gas cylinders. (CFC 5303.5.3)
16. Storage maintained 18" below height of fire sprinkler heads, 24" from ceiling (non-sprinklered). (CFC 315.3.1)
17. No storage in mechanical or electrical rooms. (CFC 315.3.3)
18. Area in front of electrical panels shall be clear for 36". (CFC 603.4)
19. Storage of combustible materials shall be maintained clear of all ignition sources (ex: water heaters, boilers, heaters, etc.). (CFC 305.1)
20. Maintain and repair any damage in materials used to protect membrane in fire-rated construction such as ceiling tiles, damaged walls, doors, etc. (CFC 703.1)
21. Repair or replace any non-operational/damaged emergency and exit lights. (CFC 1008.2 & 1013.3)
22. Building address must be legible and placed in a position that is visible from the street. (CFC 505.1)

Contact Information Required

Business Name:

Address:

Phone number:

Manager Name:

Phone number:

Email:

Building owner name:

Building owner phone number:

Billing address: