LARGE FAMILY DAYCARE CHECKLIST

 Address posted and visible from the street.
 Smoke detectors in every bedroom, and all common use areas.
 Fire extinguisher shall be mounted where readily available.
 Fire alarm with sounding device.
 Exits (2) required.
 Locks on exit doors (no knowledge).
 Solid Core, self-closing door on garage.
 Garage – One hour separation required.
 Emergency numbers posted near telephone.
 Evacuation plan posted at both exits.
 Fire drill monthly record kept on file for inspector to view.
 Gas heaters/furnaces – protected.
 Fireplaces, wood stoves, open faced heaters – shall be screened.
 Storage of flammables – shall be stored in garage/outside location
 Fire department permit posted.
 Assistant for children.
5' or fence around swimming pools